

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7210-1475:103 Page 1 of 1

CATEGORY: Flame Detector

LISTEE: Meggitt Avionics Inc., 10 Ammon Dr., Manchester, NH 03103-7406
Contact: P. Simmons (603) 669-0940 Fax (603) 669-0931

DESIGN: Model OMNIGUARD Series 660-0XXXX and 660-1XXXX UV flame detectors. Unit is a single spectrum detector utilizing the highly reliable Edison ultraviolet (UV) photon detector tube. Suitable for indoor and outdoor use in ambient temperatures range from -40°F to 257°F. Suitable for use in Class I, Division 1, Groups B, C, D (explosion-proof) and Class II, Division I, Groups E, F and G (dust ignition-proof) hazardous locations. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and FM label.

APPROVAL: Listed as flame detectors for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation.

10-30-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager